

Annexure C

PERFORMA FOR THE SAFE DRINKING WATER AND SANITARY COBDITION CERTIFICATE

NO.

Dated:

It is certified that an inspection team headed by Er. Rohit Kumar Sagar (SWSM)

(Name of Officers with Designation) from Assistant Engineer PHED

Inspected the Guru Nanak Academy, Bilaspur Road milak Rampur

(Name & Address of school) on 18/09/2026 (date of inspection) and on the basis of water

Test Report (Attached) bearing no. RMP/LAB/200 dated 21/09/2026

Of District level water Analysis & Laboratory (PHED Lab) certified that the

Guru Nanak Academy (Name of school) has safe drinking water facilities for

The Students and members of the staff of the institution. School is also maintain the hygienic sanitation

Conditions in the school building & the campus as per norms prescribed by Central /State /U.T.Govt.

This certificate is valid till 20/09/2027

Signature with Seal : [Signature]

Name : Rohit Kumar

Désignation : AE

Name & Address of the Office /Department:.....

Assistant Engineer
WSM, Rampur (UP)

To

Guru Nanak Academy
Bilaspur Road milak Rampur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies.



District Level Water Analysis Laboratory, UPJN (Rural)

14 MLT, STP, Suar Road, Ghatampur, Rampur



TC-12192

Test Report

Report Issue: - Guru Nanak Academy, Bilaspur Road,
Milak, Rampur-244901

Report No	RMP/LAB/200
Report Issue date	21.09.2026
URL NO.	TC121922500000166F
Ref. Letter No.	-

Basic Detail of Sample

Sample Name	Ground Water	Block	Milak
District	Rampur	Gram Panchayat	-
Quantity of Sample	1000 ml	Village	-
Preservation Type	Normal and Acidic	Location	School
Packaging Type	Plastic Bottle	Habitation	-
Water Source	Deep Tube Well	Date of Sampling	18.09.2026
Sample No.	C/26/09/P/08	Sample Collector	Zahid Hussain
Receiving Date	18.09.2026	Sampling Method	IS3025:part 1 (1987)
Sample Depositor	Zahid Hussain	Analysis End Date	21.09.2026
Analysis Start Date	18.09.2026		
Environmental Condition (@25 ±3°C)	26.8°C	Humidity (50±15%)	58.9%

Analysis Report

S. No	Test Parameters	Unit	Observed Value	Specified Value as Per BIS 10500:2012		Reference Method Of Analysis
				Acceptable Limit	Permissible Limit	
1	pH (@25 ±3°C)	--	7.56	6.5-8.5	No Relaxation	IS 3025(Part 11):2022(Electrometric Method)
2	TDS	Mg/L	418	500	2000	IS 3025(Part 16):2023
3	Turbidity	NTU	0.24	1	5	IS 3025(Part 10):2023
4	Colour	CU	<5	5	15	IS 3025(Part 4):2021
5	Total Hardness (as CaCO ₃)	Mg/L	342	200	600	IS 3025(Part 21):2023
6	Fluoride	Mg/L	0.214	1	1.5	APHA 24 th Edition 4500-F (C) Electrode Method 2023
7	Total Alkalinity (as CaCO ₃)	Mg/L	384	200	600	IS3025(Part 23):2023
8	Chloride	Mg/L	36.5	250	1000	IS3025(Part 32):1988
9	Calcium	Mg/L	74.0	75	200	IS3025(Part 40):2024
10	Magnesium	Mg/L	38.39	30	100	IS3025(Part 46):2023



District Level Water Analysis Laboratory, UPJN (Rural)

14 MLT, STP, Suar Road, Ghatampur, Rampur



TC-12192

11	Nitrate	Mg/L	1.112	45	No Relaxation	APHA 24th Edition :4500 NO3 (B) UV Spectrophotometric Method 2023
12	Sulphate	Mg/L	34.59	200	400	APHA 24th Edition :4500 SO4 (E) Turbidity Method: 2023
13	Iron	Mg/L	0.01	1.0	No Relaxation	APHA 24th Edition :3500 Fe (B)Phenanthroline Method: 2023

****End of The Report****


Prepared by


Reviewed BY


Authorized Signatory


Abbreviation: - Mg/L-Milligram per litter, NTU- Nephelometric Turbidity units, CU-Colour Unit, BDL-Below detection limit, NT-Not Tested, ND- Not Detected.

Remark:- The Tested Sample is Confirms Drinking Water Standard (as per IS 10500) with respect to our tested parameter Only.

NOTE	1. This Certificate Refers Only to The Particulars sample Submitted for Testing.
	2. This Certificate Shall Not Be Reproduced Except in Full, unless written Permission for the Publication of an Approved Abstract Has Been obtained From Head of Laboratory.
	3. The Test Result Reported in This Certificate are Valid at The Time of And Under the Stated Conditions of Measurements.
	4.Source Is Verified by the Laboratory.



District Level Water Analysis Laboratory, UPJN (Rural), Rampur

Water Analysis Report

Report No-RMP/LAB/B/171

Report Issue :- Guru Nanak Academy.

Date of Report- 21-09-26

Address.

Bilaspur Road, Milak, Rampur-244901

Ref.Letter No.

Basic Detail Of Sample

District	Rampur	Block	Milak
Gram Panchayat	-	Village	-
Habitation	-	Location	School
Water Source	Deep Tubewell	Sample No.	B/26/09/P/08
Quantity of Sample	1000 ML(Normal And Acidic)	Date of S.C	18/9/2026
Receiving Date	18/9/2026	Sample Collector	Zahid Hussain
Sample Depositor	Zahid Hussain	Sampling Method	IS17614 (Part 1) : 2021
Analysis Start Date	18/9/2026	Analysis End Date	21/9/2026

MICROBIOLOGICAL PARAMETERS

S.No	Analysed Parameter	Unit	Observed Value	Specified Value As Per BIS 10500:2012		Reference Method Of Analysis
				Acceptable Limit	Permissible Limit	
1	E.Coli	CFU/100 ML	0	Shall not be detectable in any 100 ml sample	No Relaxation	IS 15185:2016
2	Total Coliform	CFU/100 ML	0			IS 15185:2016
3	Residual Free Chlorine	Mg/L	0	0.2	1	IS3025 (Part 26)

(Microbiologist)

Laboratory Contact Detail-E-mail-labjalnigamgramin@gmail.com

NOTE: 1) This Certificate Refers Only to The Particular sample Submitted for Testing. (2) This Certificate Shall Not Be Reproduced Except In Full, unless written Permission for the Publication Of an Approved Abstract Has Been obtained From Head Of Laboratory (3) The Test Result Reported in This Certificate are Valid at The Time of And Under The Stated Conditions Of Measurements (4) Sample Will Be Stored Up to 7 Days (In case of Non Perishable items Only) From The Date of Issue. (5) Water with E.coli or Total Coliform count above 0 is considered unsafe for drinking.